

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5028

1. OWNER DAN Kellberg ADDRESS AT WELL LOCATION _____
MAILING ADDRESS SENTIA Court
Rd. Mountain View 89045
2. LOCATION SW 1/4 SW 1/4 Sec 4 T 10 N/S R 43E Nye County
PERMIT NO. 2 File 172119 Subdivision Name 03 761-32
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel		0	15	
wh clay		15	18	
gravel		18	20	
Brn clay		20	23	
sd		23	26	
Brn clay		26	35	
gravel	✓	35	37	
Brn clay		37	45	
gravel	✓	45	49	
Brn clay		49	73	
gravel	✓	73	76	
Brn clay		76	85	
gravel	✓	85	90	
wh clay		90	93	
gravel	✓	93	124	
Brn clay		124	129	
gravel	✓	129	135	

8. WELL CONSTRUCTION

Diameter hole 1 1/2 19/32 inches Total depth 135 feet
Casing record _____
Weight per foot _____ Thickness 1183
Diameter From To
1 1/2 inches 0 feet 20 feet
9/8 inches 52 feet 135 feet
Surface seal: Yes No Type NEAT CEMENT
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet
Perforations:
Type perforation mill slot
Size perforation 1/8" x 3"
From 85 feet to 135 feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 24 feet below land surface
Flow 80 G.P.M. P.S.I.
Water temperature 60 ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co Contractor
Address 4662 MAYNARD SPARKS NV Contractor
Nevada contractor's license number 24521
Nevada contractor's drillers number 1374
Nevada driller's license number 1442 Actual Driller
Signed Les Woytek Contractor
Date 5-11-89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Lift

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours