WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31640
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9909

1. OWNER Young Builders, Inc
MAILING ADDRESS P.O. Box 18196
Reno, Nevada 89511

ADDRESS AT WELL LOCATION
2065 Lakeshore Drive
Carson City, NV

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N S R. 20 E. Washoe County

PERMIT NO. ~~Wdy 3545~~ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand		0	4	4
Blow sand, silt, fine to course sand w/ clay layers	✓	4	98	94
Course sand w/ silt + clayseams some D.G.	✓	98	135	37
T.D. 135 feet				
Note. 10 foot blank filled with pea gravel to stop silt				

Date started May 29, 1989
Date completed May 30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	51.6		
		1	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" inches Total depth 135 feet
..... inches
..... inches
Casing record 6 5/8" steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 135 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 3/32 x 3"
From 105 feet to 125 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 14 feet below land surface
Flow 25+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address Carson City, NV 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ##
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1450
Signed Quinton Butts
By driller performing actual drilling on site or contractor
Date May 31, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627