WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31642
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12751

1. OWNER Lenny Romero
MAILING ADDRESS 4150 Partridge Lane Carson City, Nevada
ADDRESS AT WELL LOCATION New Washoe City 4095 Drake Way Carson City, Nevada

2. LOCATION NW ¼ SE ¼ Sec. 32 T. 17 N S R. 20 E. Washoe County
PERMIT NO. ~~WY 3526~~ Issued by Water Resources | 050-39310 Parcel No. | New Washoe City #5 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ sand soft		0	7	7
D.G. Soft to Medium Hardness		7	91	84
Granodiorite, hard		91	186	95
Granodiorite, fractured w/ water. Main water bearing fractures at 189, 193 & 207 feet	✓	186	200	34
Note: 10 feet pea gravel in bottom blank to stop sand coming in from bottom				
T.D. 220 feet				

Date started May 12, 1989
Date completed May 18, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed & Gravel packed with 250 psi Air Blew 16 GPM from 190 for 1½ Hours to Clean & Develop			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10¾" to 60' inches Total depth 220 feet
9½ inches
inches
Casing record 6 5/8 OD-Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	220 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 220 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 190 feet to 110 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 157 feet below land surface
Flow 16-17 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AE H Pump Co Contractor
Address Carson City, Nevada Contractor
Nevada contractor's license number issued by the State Contractor's Board 23495
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 21472
Signed Clinton R Butts
By driller performing actual drilling on site or contractor
Date May 19, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627