WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 31686
Permit No.
Basin 4-72

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9241

1. OWNER Claude Jones
MAILING ADDRESS P.O. Box93
Imlay, Nevada 89418

ADDRESS AT WELL LOCATION Imlay

2. LOCATION ¼ N. ½ ¼ Sec. 3 T T 32 N N/S R. 32 E E Pershing County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Soil brown | | 0 | 1 | 1 |
| Clay brown | | 1 | 11 | 10 |
| Clay gray, sandy | | 11 | 59 | 48 |
| Clay brown | | 59 | 64 | 5 |
| Sand brown | | 64 | 72 | 8 |
| Clay brown | | 72 | 103 | 31 |
| Gravel brown | 9 | 103 | 112 | 9 |

'89 MAY 24 A10:26
STATE ENGINEER'S OFFICE

Date started April 10, 1989
Date completed April 23, 1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 40 Draw down 3 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8" inches Total depth 112' feet
inches
inches
Casing record
Weight per foot 18 lbs. Thickness .188

| Diameter | From | To |
|---|---|---|
| 8" inches | 0' feet | 112' feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation tourch
Size perforation 1/8" by 5"
From 100' feet to 112' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22' feet below land surface
Flow good G.P.M. P.S.I.
Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. & R. Drilling (Contractor)
Address P.O. Box 1982 Wmca., Nv. 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 017721
Nevada contractor's driller's number issued by the Division of Water Resources 1190
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190
Signed Thomas [illegible] (By driller performing actual drilling on site or contractor)
Date May 21, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627