WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31770
Permit No.
Basin 8-89

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12754

1. OWNER Herbert Witherspoon
MAILING ADDRESS 3645 Pershing Lane Carson City, NV
ADDRESS AT WELL LOCATION 1815 East Lake Blvd Carson City, NV

2. LOCATION SE ¼ SW ¼ Sec. 30 T. 17 N. S.R. 20 E. Washoe County
PERMIT NO. Wcty 3554 (Issued by Water Resources) | 50-369-01 (Parcel No.) | New Washoe City #5 (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/blow sand		0	7	7
Sand with very fine silt		7	52	45
D.G. weathered with sand to very fine		52	81	29
D.G. Medium, Hard to hard, weathered	✓	81	97	16
Fractured Granodiorite, hard with water in fractures	✓	97	130	33
Note: 6 feet pea gravel in blank section	Plugged By Well Log 125056			
	Replaced By Well Log 125057			
T.D. 130 Ft				

Date started June 14, 1989
Date completed June 20, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Circulated clean water to remove drill mud & gravel pack. Developed with 250 psi air for 3 hours Blew 25+ GPM from 110 feet			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12¼ to 70' inches Total depth 130 feet
10¾ inches
____ inches
Casing record 6⅝" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 130 feet

Perforations:
Type perforation Factory Slotted
Size perforation 3/32" x 3"
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow 25+ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P & H Pump Co (Contractor)
Address 5351 Hiway 50 E #3 Carson City Nevada 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton Butts (By driller performing actual drilling on site or contractor)
Date June 21, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627