31777

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31777
Permit No.
Basin G-87 Truckee Meadows

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12492

1. OWNER: GARY & JANICE LUBRA
MAILING ADDRESS: 11895 Thomas Creek Road, Reno, NV 89511
ADDRESS AT WELL LOCATION: Same

2. LOCATION: SE ¼ SE ¼ Sec. 13 T. 18N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 40-750-05 | Subdivision Name: SW Reno

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay with boulders		0	3	3
Soft sand w/bigger bolders		3	11	8
Sand & gravels w/bolders		11	21	10
Bolder		21	23	2
Bolders & gravels not much clay		23	70	47
Bolder		70	73	3
Sand & gravels some bolders		73	95	22
Soft sand		95	112	17
Gravels somee smaller bolders		112	141	29
Bolder		141	147	6
Sand & gravels with streaks of brown clay	X	147	159	12
Brown clay with bolder & gravels		159	164	5
Soft zone	X	164	188	24
Bolder & gravels (slow going)		188	225	37
Soft zone	X	225	246	21
Bolders & gravels		246	264	19

Date started 6-13-89, 19
Date completed 6-15-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 265 feet
____ inches
____ inches
Casing record 265' steel casing installed.
Weight per foot ____ Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	XX 265 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 53 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 53 feet to 265 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 155 feet to 195 feet
From 235 feet to 255 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level --- feet below land surface
Flow 40 G.P.M. ____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Wayne Drilling, Inc.
Address (Contractor) P.O. Box 12370, Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 20, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627