

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 12654

PRINT OR TYPE ONLY

1. OWNER Joe & Sharon Vasquez ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1753 Union St 260 Agua Fria
Sparks, Nv 89431 Parcel D of Map 1804
 2. LOCATION SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 19 T. 21 N/S R. 21 E Washoe County
 PERMIT NO. 076-371-43 Spanish Springs 19-1-1-9
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK 4. PROPOSED USE 5. TYPE WELL
 New Well Recondition Domestic Irrigation Test Cable Rotary
 Deepen Other Municipal Industrial Stock Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Volcanic cobbles & sands | | 0 | 4 | 4 |
| Tan yellow white D.G. | | 4 | 57 | 53 |
| Red clay with red green yellow gravels | | 57 | 72 | 15 |
| Red clay with some red & green volcanic rock | | 72 | 205 | 133 |
| Brown & red volcanic rock | | 205 | 240 | 35 |
| T.D. 240 ft | | | | |

8. 10" - 60' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 240 feet
 Casing record 6 5/8 inch Thickness .156
 Weight per foot 10.78
 Diameter 6 5/8 inches + 1 1/2 From 240 To _____ feet
 Surface seal: Yes No Type grout
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 240 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 6/12/89, 19_____
 Date completed 6/12/89, 19_____
 7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------------------------------|--------|-----------|------------------|
| Blew with air to clean and develop. | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 150 feet below land surface
 Flow 20+ G.P.M. P.S.I. _____
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 6/15/89

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours