

OFFICE USE ONLY  
 Log No. 31818  
 Permit No. \_\_\_\_\_  
 Basin G-25 Sp. Springs V.  
 12635

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Will & Phyllis Brown ADDRESS AT WELL LOCATION 2129 Cielo Vista  
 MAILING ADDRESS 1225 Greenbrae Map 23 of Survey 477224  
Sparks, Nv 89431  
 2. LOCATION SW 1/4 SE NW 1/4 Sec. 31 T. 21 N/S R. 21 E Washoe County  
 PERMIT NO. 076-390-25 - Spanish Springs  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Yellow brown white fine sands		0	16	16
Yellow brown white tan D.G. sands & gravels with brown		16	320	304
T.D. 320 feet				
deepened by well log # 112609				
39.644756°N NAD22 D.D.				
119.675514°W - GPS -				

8. 10" - 60" WELL CONSTRUCTION  
 Diameter 8 1/2 inches Total depth 318 feet  
 Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>318</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 318 feet

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 X 3  
 From 278 feet to 298 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5/8/89, 19\_\_\_\_\_  
 Date completed 5/9/89, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop			
		<u>81.0W 07.00 68.</u>	

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 143 feet below land surface  
 Flow 10 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 5/24/89