WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

#2

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31868
Permit No. 37398
Basin 10-156 Hot Creek V.

NOTICE OF INTENT NO. 5629

1. OWNER Joe Fallini
MAILING ADDRESS Twin Springs Ranch
via Tonopah, NV 89049
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 13 T. 5 N. R. 50 E. Nye County
PERMIT NO. 37398 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top 80' drilled previously by owner				
Gravel & sand		62	90	28
Cem. sand & gravel		90	100	10
Cem. sand & clay		100	110	10
Cem. sand & gravel		110	115	5
Cem. gravel, sandy clay		115	190	75
Sand & grav.,some clay str.		190	230	40
Cem. gravel & clay		230	270	40
Clay with grav. stringers		270	330	60
White clay & cem. sand		330	375	45
Hard blue clay, white clay		375	410	35

'89 JUL 13 A9:49
STATE

Date started March 14, 1989
Date completed March 20, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 24 inches Total depth 410 feet
inches
inches
Casing record
Weight per foot Thickness .250

Diameter	From	To
16 inches	+1 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal Installed previously feet
Gravel packed: Yes ☒ No ☐
Gravel packed from Surface feet to 410 feet

Perforations:
Type perforation Louvers
Size perforation 16 rows 5/16x2" 3" vert. spacing
From 139 feet to 399 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. Contractor
Address 4185 West Harmon Las Vegas, NV 89103 Contractor
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1567
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date July 11, 1989