WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31876
Permit No.
Basin 9-106

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Doug Hellman
MAILING ADDRESS P.O. Box 2658
Stateline Nevada 89449

ADDRESS AT WELL LOCATION
1553 Alta Vista
Gardnerville Nevada

2. LOCATION NE ¼ SE ¼ Sec. 13 T 10 N/S R 22 E Douglas County
PERMIT NO. Issued by Water Resources
37-563-25 Parcel No.
Hellbrick Highlands 2 + 3 Blk C Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/small boulders, cracked clays		0	6	6
Cemented gravel with clay seams		6	138	132
Gravel seams w/water		138	160	22
T.D. 160 feet				

Date started July 6, 1989
Date completed July 10, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Attached pump, clean water to gravel pack, remove drill mud, developed w/350 psi air, blew 20-22 GPM from 120 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ to 60 inches Total depth 160 feet
7¾ inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 160 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 5/32 + 3"
From 145 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow 20-22 G.P.M. Good P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co
Contractor
Address 751 Hwy 50 E #43
Carson City Nevada
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2472
Signed
By driller performing actual drilling on-site or contractor
Date July 11, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627