

OFFICE USE ONLY  
 Log No. 31880  
 Permit No. \_\_\_\_\_  
 Basin 2-106

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 12867

PRINT OR TYPE ONLY

1. OWNER Pine Nut Lodge (Don Scott) ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 744 COWPER ST. PALO ALTO, Ca. 94301 Hiway 395 AT TOPAZ LAKE  
 2. LOCATION S 1/2 SW 1/4 Sec. 29 T. 10 N/S R. 22 E Douglas County  
 PERMIT NO. 39 142 03 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  Commercial  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ROCKS & BOULDERS		0	95	95
ROCK & CLAY		95	130	35
HARD BOULDERS		130	155	25
ROCK & CLAY		155	175	20
BROKEN ROCK & CLAY	X	175	215	40
BROKEN ROCK W/ FRACTURES		215	255	25
CLAY		255	265	10
BROKEN ROCK W/ FRACTURES		265	328	63
CLAY		328	330	2

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 330 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 8" to 79' 6" from 70' to 330'  
 Weight per foot \_\_\_\_\_ Thickness 156  

Diameter	From	To
8 inches	0 feet	79 feet
6 inches	70 feet	330 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 1/2" x 3" 6 pr/ft  
 From 190 feet to 210 feet  
 From 230 feet to 250 feet  
 From 270 feet to 290 feet  
 From 310 feet to 330 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-26, 1989  
 Date completed 6-30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 150 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. 75-100 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Energy Exploration Contractor  
 Address PO Box 1538 Minden NV 89423 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21491  
 Nevada contractor's driller's number issued by the Division of Water Resources 1407  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407  
 Signed Don Wood  
 By driller performing actual drilling on site or contractor  
 Date 6-30-89