WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 31886
Permit No. 18804
Basin 9-107

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10786

1. OWNER HUNEWILL LAND & LIVESTOCK
MAILING ADDRESS 260 HUNEWILL LANE
WELLINGTON, NEVADA 89444

ADDRESS AT WELL LOCATION SAME

2. LOCATION NE ¼ NE ¼ Sec. 27 T. 12 (N/S) R. 23 E MDBM LYON County
PERMIT NO. 18804 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, gravel & topsoil		0	40	40
Blue sand		40	80	40
Course blue sand		80	100	20
Course sand & fine gravel (blue/white)		100	180	80
Course sand, fine gravel w/ layers of sandy blue clay		180	280	100
Sandy clay w/ thin layers of sand		280	300	20

JUL 20 AM 10:52 '89 STATE ENGINEER

Date started June 8, 1989
Date completed June 15, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 24 inches Total depth 300 feet
..... inches
..... inches
Casing record 16 inch O.D. X 1/4 inch wall
Weight per foot 42.05 Thickness .....

Diameter	From	To
16 inches	+1 feet	100 feet
inches	feet	feet
inches	180 feet	240 feet
inches	feet	feet
inches	280 feet	300 feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement sand grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 300 feet
Wadsworth 3/8 inch minus well rock
Perforations:
Type perforation milled
Size perforation 3 inch X 1/8 inch Dbl. Std. Sp.
From 100 feet to 180 feet
From ..... feet to ..... feet
From 240 feet to 280 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 26 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGAITON COMPANY (Contractor)
Address 9955 N. VIRGINIA ST., RENO, NV. 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1388/1482
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JULY 18, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627