WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31954
Permit No.
Basin 4-49

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12411

1. OWNER ROYCE L. HACKWORTH
MAILING ADDRESS 1031 Dotta Dr.
Elko, NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 35 N/S R. 56 E Elko County
PERMIT NO. (Issued by Water Resources) Lot 8 Blk 42 (Parcel No.) Meadow Valley Ranchos Unit #3 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0'	10'	10'
Clay		10'	25'	15'
Gravel w/clay		25'	40'	15'
Clay & gravel		40'	65'	25'
Clay		65'	100'	35'
Clay w/gravel		100'	110'	10'
Gravel w/clay		110'	145'	35'
Clay w/gravel		145'	175'	30'
Gravel w/clay		175'	185'	10'
Clay w/gravel		185'	210'	25'
Gravel		210'	285'	75'
First water at 65'				

JUL 12 A9:21
STATE ENGINEER'S OFFICE

Date started 6-10 '89, 1989
Date completed 6-11, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Test	12 gpm		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 285 feet
inches
inches
Casing record
Weight per foot 2.95# Thickness .156

Diameter	From	To
6 5/8 inches	+1½ feet	264 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 4 to 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from ~~264~~ 50 feet to 285 feet

Perforations:
Type perforation Machine slots
Size perforation 1/8" x 3" x 6 row
From 264 feet to 285 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1408
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-10-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627