WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 31987
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12451

1. OWNER Jack Gardner
MAILING ADDRESS Box 1700
Zephyr Cove, Nev 89448
ADDRESS AT WELL LOCATION Parcel #5
Gardnerville, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 25 T. 12 N/S R. 19 E Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 19-300-21 Subdivision Name Day Canyon Estates

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, tight clay		0	2	2
Sand, gravels, w/ cobbles to 4"		2	17	15
Sand, gravels w/ clay seams		17	90	73
Tight clay seam		90	92	2
D.G. Loose to hard, small amount of water	–	92	101	9
Granodiorite, hard with fractures carrying water	–	101	140	39
T.D. 140 Ft				

Date started Aug 28, 1989
Date completed Aug 29, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw-Down	After Hours Pump
Flushed with clear water to remove drill mud & small pack. Developed with air for 1 hour to clean. Est. 40-45 GPM from 130 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION 12/4/650
Diameter 9 7/8 inches Total depth 140 feet
..... inches
..... inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 9/32" x 3"
From 120 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 24 feet below land surface
Flow 40-45 G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed George Hummell (By driller performing actual drilling on site or contractor)
Date 8/30/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627