

OFFICE USE ONLY  
 Log No. **32000T**  
 Permit No. **5039**  
 Basin **137-B Big Smoky V.**

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. **5039**

1. OWNER R.O. Livestock ADDRESS AT WELL LOCATION Hwy 376  
 MAILING ADDRESS P.O. Box 2050 Round Mountain, NV.  
King City, NV 89330  
 2. LOCATION NE 1/4 NE 1/4 Sec. 8 T. 12 N/R. 43 E Nye County  
 PERMIT NO. R.O. Ranch Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	4	
gravel		4	35	
clay		35	40	
gravel		40	48	
clay		48	52	
gravel	✓	52	67	
Sand		67	69	
gravel		69	93	
clay		93	94	
gravel	✓	94	135	

RECEIVED  
 STATE ENGINEERS OFFICE  
 1989 AUG -2 AIO 42

8. WELL CONSTRUCTION  
 Diameter hole 1 1/2 inches Total depth 135 feet  
 Gasing record  
 Weight per foot Thickness 188  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>135</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes  No  Type Neat Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation milled slot  
 Size perforation 1/8 x 3"  
 From 100 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Flow 60 G.P.M. P.S.I.  
 Water temperature Cold ° F. Quality good

Date started 7-11, 1989  
 Date completed 7-12, 1989

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Waytek Drilling Contractor  
 Address 4662 Maynard Sparks NV Contractor  
 Nevada contractor's license number 24521  
 Nevada contractor's drillers number 1374  
 Nevada driller's license number 1442 Actual Driller  
 Signed Les Waytek Contractor  
 Date 7-27-89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

N/A

BAILER TEST Air Lift  
 G.P.M. Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours