WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

SECTION 11 cba

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32004
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 17440

1. OWNER Pulte Bros Corp
MAILING ADDRESS Box 707
Dayton Nevada 89403
ADDRESS AT WELL LOCATION 3400 Carson Street
Minden Nevada

2. LOCATION SE ¼ NW ¼ Sec. 14 T. 14N. N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 15-09206 (Parcel No.) Pine View Estates #5 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	8	8
Light brown Clay w/ small gravel & HARD		8	90	82
Clay & interspersed soft Dirt		90	97	7
Fractured Granodiorite Carrying water		97	126	29
T.D. 126				

STATE ENGINEERS OFFICE RECEIVED AUG 15 P 4:10 '89

Date started Aug 9, 1989
Date completed Aug 11, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed & Tested Bailed			
10 to 120 feet		16	
Flow	20-22	8 PM	Flow
110 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" to 60' 9 5/8" inches Total depth 126 feet
Casing record 6 5/8" Steel
Weight per foot ..... Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	126 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 54 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 54 feet to 126 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/8 x 3"
From 106 feet to 126 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 19 feet below land surface
Flow 20-22 G.P.M. ..... P.S.I.
Water temperature 62 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pat H Shaw Co (Contractor)
Address 1600 Carson St 89703 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 6375
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1470
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Aug 11, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627