

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10915

1. OWNER Don Woodward ADDRESS AT WELL LOCATION Sicoma Sunset  
 MAILING ADDRESS Box 724 Heights Unit 2  
Minden Nev 89423 North E 28 Douglas County  
 2. LOCATION 5 1/4 1/4 Sec 34 T. 13 N. 28 E. 28 Douglas County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                                   | Water Strata | From | To  | Thick-ness |
|--|--------------|------|-----|------------|
| Topsoil                                    |              | 0    | 12  | 12         |
| Sand and gravel                            | ✓            | 12   | 28  | 16         |
| Yellow sandy clay                          | ✓            | 28   | 45  | 17         |
| gravel, coarse sand                        | ✓            | 45   | 85  | 40         |
| Yellow clay                                |              | 85   | 95  | 10         |
| Coarse gravel and some coarse sand stratas | ✓            | 95   | 175 | 80         |

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 175 feet

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 1.55

| Diameter        | From          | To              |
|-----------------|---------------|-----------------|
| <u>8</u> inches | <u>0</u> feet | <u>175</u> feet |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |

Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation 1 story saw slot  
 Size perforation 3/32" x 3"  
 From 135 feet to 175 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-18-1989  
 Date completed 5-25-1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| _____    | _____  | _____     | _____            |
| _____    | _____  | _____     | _____            |
| _____    | _____  | _____     | _____            |

9. WATER LEVEL

Static water level 20 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EMDL Co, INC Contractor  
 Address Box 97, Summit, Nev. 89430 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 24149  
 Nevada contractor's driller's number issued by the Division of Water Resources 24149  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 710  
 Signed Edmund Miller By driller performing actual drilling on site or contractor  
 Date 8-10-89

BAILER TEST

G.P.M. 20 Draw down 30 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours