WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 32008
Permit No.
Basin 137B-B16 Smoky V.

**PRINT OR TYPE ONLY**

NOTICE OF INTENT NO. 11756

1. OWNER Frank J Dziurda
MAILING ADDRESS 1095 Monitor Dr. Reno NV. 89521
ADDRESS AT WELL LOCATION Box 12 B Round mo. NV. 89045

2. LOCATION SW ¼ SE ¼ Sec. 30 T. 13 N/S R. 43 E. N/E. County
PERMIT NO. 51563 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☒ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Soil | | 0 | 1 | 1 |
| Sand & gravel | | 1 | 9 | 8 |
| Sand gravel some clay | | 9 | 59 | 50 |
| Cemented sand & gravel with zeolite | | 59 | 240 | 181 |
| Bedrock Clay | | | | |

RECEIVED STATE ENGINEERS OFFICE 89 AUG -2 P2:23

Date started 1- June, 1989
Date completed 7-25-, 1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 1,000 | 100' | 24 |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 24" inches Total depth 240 feet
inches
inches
Casing record
Weight per foot Thickness .250

| Diameter | From | To |
|---|---|---|
| 16 inches | +1 feet | 240 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation Mill cuts.
Size perforation 18 x 2½
From 50 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 25 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 60° °F Quality ok.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Oasis Drilling Inc. (Contractor)
Address Po. Box 21421 Carson City NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023129
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
Signed T. Ann (By driller performing actual drilling on site or contractor)
Date 7-25-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627