WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32015
Permit No. 46384
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12765

1. OWNER Julius Bunkowski
MAILING ADDRESS Hiway 50 East
Dayton Nevada

ADDRESS AT WELL LOCATION Lincoln and Rd
Mound House Nevada

2. LOCATION NW ¼ SW ¼ Sec. 24 T. 16 (N) S R. 20 E. Lyon County

PERMIT NO. 46384 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill material		134	140	6
Broken hard Shale. Very abrasive.	✓	140	240	100
Major fractures carrying water at 187-88, 204-205, 227-229 and 236				
Note: Set liner to 240 feet and left 20 feet up inside 8 5/8" Outer Casing	Plugged by 105 91832			
T.D. 240 ft				
Deepening of log # 20478				

Date started July 22, 1989
Date completed July 23, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with 250 psi air for 3 Hours to clean & remove drill foam additive			
Static level @ 160 ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 7 7/8 inches Total depth 240 feet
7 7/8 inches
inches
Casing record 6 5/8 Steel
Weight per foot 17 Thickness .156

Diameter	From	To
6 5/8 inches	120 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐
Gravel packed from Unknown feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 140 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 160 feet below land surface
Flow 30 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name D&H Pump Co (Contractor)
Address Carson City Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 25, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

Log No. 32015
Permit No. 46384
Basin 2-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12765

1. OWNER Julius Bunkowski
MAILING ADDRESS Highway 50 East
Dayton Nevada
ADDRESS OF WELL LOCATION End of Lincoln Rd
Round House Nevada
2. LOCATION NE ¼ SW ¼ Sec. 24 T. 16 N S R. 20 E Lyon County
PERMIT NO. 46384 Issued by Water Resources
Parcel No.
Subdivision Name

3. TYPE OF WORK: New Well ☐ Recondition ☐ Deepen ☑ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill material		134	140	6
Broken hard Shale / very abrasive	✓	140	240	100
Major fractures Carrying water at 187 & 188.				
204-205, 227-229 and 236		Original Log Logs		
Note: Set 16 feet to 240 feet and left 20 feet of 8 inside 8 5/8 casing				
Plugged by log #46322				
T.D. 240 ft				
Deepening of log # 20978				

Date started July 22, 1988
Date completed July 25, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed drill hole for 3 hours to clean out drill from drilling	30 gpm	250 feet	
Static level to start			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 7 7/8 inches Total depth 240 feet
Casing record 6 5/8 Steel
Weight per foot 11.7 Thickness .1155

Diameter	From	To
6 5/8 inches	120 feet	220 feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from Unknown to ____ feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 5/16 x 3"
From 140 feet to 240 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 160 feet below land surface
Flow 30 G.P.M. ____ P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H&H Pump Co
Address Carson City Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller H&H
Signed Lawton Fields (By driller performing actual drilling on site or contractor)
Date July 25, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 10-85) 10/85