WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32022
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12764

1. OWNER K+K Builders
MAILING ADDRESS P.O. Box 21194
Reno, Nevada 89515

ADDRESS AT WELL LOCATION
120 Esmeralda
Carson City, NV 89705

2. LOCATION SW ¼ SW ¼ Sec. 32 T. 17 N S.R. 20 E. Washoe County
PERMIT NO. ~~Wtty 5582~~ Issued by Water Resources | Parcel No. | New Washoe City #5 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden & blow sand		0	8	8
Soft, partially cemented sand with small gravels		8	19	11
Fairly tight compacted sand & d.g.		19	137	118
Granodiorite, hard, with fractures carrying water	✓	137	180	43
Major water @ 137, 167, 171-173 feet				
T.D. 180				

Date started July 20, 1989
Date completed July 24, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
developed & gravel packed with 250 psi air Blew 16-18 GPM from 170' for 3 hours to develop & clean			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ to 60' inches Total depth 180 feet
9½ inches
7⅞ inches
Casing record 6⅝" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete Redi-mix
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 180 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 160 feet to 180 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow 16-18 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co
Contractor
Address 5551 Hiway 50E Carson City, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton Britt
By driller performing actual drilling on site or contractor
Date July 25, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627