WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32034
Permit No.
Basin 6-83

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12890

1. OWNER: BOB WOFSE
MAILING ADDRESS: 135 Lapham Way, San Francisco, CA 94112
ADDRESS AT WELL LOCATION: Lot #277 Cartwright, Virginia City Highlands, NV 89440

2. LOCATION: NW ¼ NE ¼ Sec. 31 T. 18 N N/S R. 21 E. Storey County
PERMIT NO. (Issued by Water Resources) Parcel No. Virginia City Highlands (Subdivision Name)

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown andasite		1	63	62
Gray andasite		63	107	44
Purple andasite		107	188	81
Fracture (app 2 GPM)	X	188	189	1
Purple andasite		189	190	1
Gray andsite		190	205	15
Purple andasite		205	265	60
Fracture	X	265	266	1
Purple andasite		266	275	9

RECEIVED 89 AUG -4 AM 10:07 STATE ENGINEERS OFFICE

Date started 7-24-89, 19
Date completed 7-26-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 275 feet
inches
inches
Casing record 275' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	275 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 53 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 53 feet to 275 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 175 feet to 195 feet
From 255 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 168 feet below land surface
Flow 12 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 31, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627