WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32062
Permit No.
Basin 7-926

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12472

1. OWNER PAT McALINDEN
MAILING ADDRESS 4325 Indian Lane
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County

PERMIT NO. _____ (Issued by Water Resources) | Parcel No. | Golden Valley (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	½	½
Brown clay with DC		½	105	104½
Weathered granite		105	145	40
White granite		145	165	20
Soft zone (NO WATER)		165	166	1
White granite		166	180	14
Soft zone with white clay		180	188	8
Wheathered granite		188	194	6
Soft zone (NO WATER)		194	197	3
Wheathered granite		197	204	7
Soft zone		204	250	46

'89 AUG -4 A10:07
RECEIVED
STATE ENGINEERS OFFICE

Date started 7-28-89, 19
Date completed 7-28-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 250 feet
_____ inches
_____ inches

Casing record 250' steel casing instaalled.
Weight per foot _____ Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 51 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 51 feet to 250 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 203 feet to 243 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 108 feet below land surface
Flow 22 G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada contractor's driller's number issued by the Division of Water Resources 908

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] By driller performing actual drilling on site or contractor

Date July 31, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O) 627