

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2729

1. OWNER Devere Collierwood ADDRESS AT WELL LOCATION Collinwood  
 MAILING ADDRESS Box 241 Eureka Nev. Lane Eureka Nev.

2. LOCATION S/W 1/4 S/W 1/4 Sec 32 T 20 N 9 R 53 E Eureka County

PERMIT NO. 19411 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/>	4. PROPOSED USE Domestic <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/>	5. TYPE WELL Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Other <input type="checkbox"/>
--	---	---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	5	5
Hard pan		5	8	3
Fine sand		8	45	37
Boulders - sand		45	55	10
Cemented gravel		55	130	75
gravel - sand		130	140	10
Cemented Gravel		140	180	40
Cemented Gravel - streaks gravel	X	180	280	100
Gravel streaks cement	X	280	320	40
sand - Gravel	X	320	340	20
Clay - sand		340	350	10

'89 AUG -7 110:36  
 RECEIVED  
 STATE ENGINEERS OFFICE  
 JUN 28 1989  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION

Diameter 26 inches Total depth 350 feet  
21 inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 250

Diameter	From	To
<u>16</u> inches	<u>0</u> feet	<u>350</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 350 feet

Perforations:  
 Type perforation factory  
 Size perforation 1/8 x 6"  
 From 180 feet to 350 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-21-89, 19\_\_\_\_\_  
 Date completed 6-23-89, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 30 Draw down 0 feet 6 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 150 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Contractor  
 Address Box 470 Panaca Nev 89043 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 020864  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed Mike Darr  
 By driller performing actual drilling on site or contractor  
 Date 6-25-89