

OFFICE USE ONLY  
 Log No. 32083  
 Permit No. \_\_\_\_\_  
 Basin 4-48

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 12512

PRINT OR TYPE ONLY

1. OWNER Howard Statfs ADDRESS AT WELL LOCATION Lot 1 B/K/F  
 MAILING ADDRESS Box 16 14 Western Hills Subdivision  
 2. LOCATION 1/4 Sec 35 T 23 N/S R 55 E 2 1/2 C County Clark  
 PERMIT NO. N/A Parcel No. 77-005-09-8 Subdivision Name Western Hills MDB & M.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Rotary  Other

6. LITHOLOGIC LOG

| Material                | Water Strata | From | To | Thick-ness |
|-------------------------|--------------|------|----|------------|
| Reddish-brown sandstone |              | 0    | 5  | 5          |
| Reddish-brown sandstone |              | 5    | 30 | 25         |
| Light tan clay          |              | 30   | 35 | 5          |
| Light tan clay          |              | 35   | 45 | 10         |
| Light tan clay          |              | 45   | 55 | 10         |
| Light tan clay          |              | 55   | 75 | 20         |

8. WELL CONSTRUCTION

Diameter 10" inches Total depth 13.2 feet

Casing record 6 7/8" x 156'

| Diameter             | From          | To               |
|----------------------|---------------|------------------|
| <u>6 7/8" inches</u> | <u>0 feet</u> | <u>13.1 feet</u> |
| _____ inches         | _____ feet    | _____ feet       |
| _____ inches         | _____ feet    | _____ feet       |
| _____ inches         | _____ feet    | _____ feet       |
| _____ inches         | _____ feet    | _____ feet       |
| _____ inches         | _____ feet    | _____ feet       |

Surface seal: Yes  No  Type concrete

Depth of seal 4' - 50" feet

Gravel packed: Yes  No

Gravel packed from 50' feet to 131' feet

Perforations:  
 Type perforation touch out  
 Size perforation 3/8" 4 slots in 4' slots  
 From 11' feet to 131' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7/28 1989  
 Date completed 7/29 1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
|        |           |      |       |
|        |           |      |       |
|        |           |      |       |

9. WATER LEVEL

Static water level 3' feet below land surface

Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds Contractor

Address Box 402 Wells NV 89735 Contractor

Nevada contractor's license number issued by the State Contractor's Board 014410

Nevada contractor's driller's number issued by the Division of Water Resources 1390

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1585

Signed Russell Boley  
 By driller performing actual drilling on site or contractor

Date 7/31/89