WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32085
Permit No.
Basin 4-45

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 0733

1. OWNER MARION Hill
MAILING ADDRESS 191 SUN MOUNTAIN LANE
ELKO, NV 89801

ADDRESS AT WELL LOCATION 191 SUN mountain LANE
Pleasant Valley EST Lot 10 Blk B

2. LOCATION NW ¼ NW ¼ Sec. 26 T. 33 N/S R. 57 E. ELKO County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Pleasant Valley EST Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	2'	
SAND Gravel		2'	40'	
Cement SAND STONE		40'	75'	
Gravel	water	75'	80'	5'
Cemented SAND STONE		80'	114'	
Soft Clay		114'	130'	
Cemented SAND STONE		130'	150'	

Date started 7-17, 1989
Date completed 7-20, 1989

STATE ENGINEERS OFFICE
RECEIVED
AUG 23 AM 11:11
89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 35 Air Test Draw down 58 feet 2 hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 150 feet
10" Hole inches
inches
Casing record 6" STEEL
Weight per foot ____ Thickness .156"

Diameter	From	To
6" inches	+ 1½ feet	150' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Slots
Size perforation 3/16 - 3"
From 110' feet to 150' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 42' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling co (Contractor)
Address 357 West River ST Elko (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 20684
Nevada contractor's driller's number issued by the Division of Water Resources 904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed Shawl C Fuller (By driller performing actual drilling on site or contractor)
Date 7-22-89

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627