

OFFICE USE ONLY
 Log No. 32103
 Permit No. _____
 Basin _____

108-NIBERS 3678
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 12106

OWNER Butch Peri
 MAILING ADDRESS 430 Hwy 339
Yerington, Nevada 89447
 ADDRESS AT WELL LOCATION 7 East Purcel Lane
 LOCATION SW of SW Section 13 36
13 S R. 25 E. Lyon County
 PERMIT NO. NA 12-011-11
 Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam top soil		0	4	4
Coarse sand		4	5	1
Sandy brown clay		5	42	37
Sand & gravel		42	52	10
Sandy brown clay w/s rocks imbedded		52	75	23
Hard clay w/ rocks imbedded		75	85	10
Soft brown clay		85	100	15
Hard clay w/s rock		100	112	12

Plugged by well log # 117289
 30 OCT 17 12:06
 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Diameter 8 inches Total depth 112 feet
 Casing record 8
 Weight per foot Dbl row perf .188 Thickness 1/4 Blank

Diameter	From	To
8" Blank inches	0	72
8" Dbl. perf. inches	72	112

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation mill slot 8"
 Size perforation 1/8 X 2 1/2
 From 7.2 feet to 112 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Address P.O. Box 592 Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada contractor's driller's number issued by the Division of Water Resources C-23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
 Signed _____
 Date 8-14-89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 40 Draw down 25 feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours