WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32132
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13414

1. OWNER Harold Rosso
MAILING ADDRESS Los Angeles, Calif
ADDRESS AT WELL LOCATION No address Pine Valley Estates Gardnerville, Nevada

2. LOCATION NE ¼ NW ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name: Pine Valley Estates

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/clay and cobbles		0	7	7
Andesite, fractured, w/clay layers		7	40	33
Andesite, hard, to bottom with fractures carrying water 2GPM @ 200', highly fractured w/water from 220-240'	✓	40	240	200
Major water from 220-240				
T.D. 240'				

Date started Sept 20, 1989
Date completed Sept 27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed gravel packed with air. Blew 20-23 GPM from 220' for 2 Hours	89 SEP 28 A9:23		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 1/2 to 11 1/2 inches Total depth 240 feet
Casing record Steel 6 5/8
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 220 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 160' feet below land surface
Flow 20-23 G.P.M. ..... P.S.I.
Water temperature Cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address A & H PUMP CO. 5551 Hwy. 50 East #3 Carson City, Nevada 89701 Contractor
Nevada contractor's license number 883-0459 883-4[illegible] 885-1889 [illegible]295
Nevada contractor's drillers number
Nevada driller's license number 1535 Actual Driller
Signed Jerald Grinnell Contractor
Date Sept. 28, 1989

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434