WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32143
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13413

1. OWNER Robert Brodie
MAILING ADDRESS 2341 Main St
Genoa, Nevada

ADDRESS AT WELL LOCATION 227 Foothill Meadow Court
Genoa, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. 17-034-[illegible] Issued by Water Resources Parcel No. 20 None Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden & Top Soil		0	12	12
Gravels & Sand with tight dark colored Clay Seams		12	82	70
Sand with Clay Stringers 2"-4" thickness		82	87	5
Gravels with Sand & Clay	✓	87	96	9
Clean Gravel to 2" with fine to Course Sand, iron Pyrite	✓	96	120	24
T.D. 120				

Note: 3' Pea Gravel in bottom to inhibit pyrite from Entering

Date started Sept 12, 1989
Date completed Sept 13, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Chemicals to remove mud & gravel pack. Developed with 250 psi air for 2½ hrs. Blowing from 100 ft 40± GPM			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12" to 50 inches Total depth 120 feet
10¾ inches
inches
Casing record 6⅝" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	72 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 feet below land surface
Flow 40 G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address Carson City, Nv 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald Phinnell
By driller performing actual drilling on site or contractor
Date Sept 15, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627