WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32150
Permit No. 52504
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10159

1. OWNER BENTLY NEVADA CORPORATION
MAILING ADDRESS 1617 WATER STREET
MINDEN, NEVADA 89423

ADDRESS AT WELL LOCATION NORTHEAST MINDEN - JOHNSON LANE AREA

2. LOCATION ~~NW~~ SE ¼ ~~NW~~ SE ¼ Sec. 36 T. 13 (N/S) R. 20 E. DOUGLAS County

PERMIT NO. 50651 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. MW 17B PROPOSED USE MONITOR
Domestic [ ] Irrigation [ ] Test [X]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALLUVIAL FORMATIONS:				
sand, gravel & clays		0	75	75

'89 SEP 19 A10:09
STATE ENGINEER'S OFFICE

Date started July 10, 1988
Date completed August 10, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9-7/8 inches Total depth 75 feet
..... inches
..... inches
Casing record 6-5/8 inch x 1/4 inch mild steel
Weight per foot 17.02 Thickness .....

Diameter	From	To
..... inches	..... feet	..... feet
6 inches	+1 feet	75 feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes [X] No [ ] Type neat cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 53 feet to 75 feet

Perforations:
Type perforation 6 inch stainless steel screen
Size perforation .035 inch
From ..... feet to ..... feet
From 55 feet to 75 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 11.7 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 N. Virginia St., Reno, Nv. 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 11, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627