

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13316

1. OWNER Hue Stockton ADDRESS AT WELL LOCATION _____
MAILING ADDRESS PO Box 159 Minden NV 89423 2639 Squires
2. LOCATION NW 1/4 SE 1/4 Sec 34 T 14 N/S R 20 E Douglas County
PERMIT NO. _____ Parcel No. _____ Subdivision Name Johnson Lane

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>45</u>	
<u>Sand & gravel</u>		<u>45</u>	<u>65</u>	
<u>Sand</u>		<u>65</u>	<u>110</u>	
<u>Clay Sand & gravel</u>	<input checked="" type="checkbox"/>	<u>110</u>	<u>130</u>	
<u>Gravel & rocks</u>	<input checked="" type="checkbox"/>	<u>130</u>	<u>140</u>	
<u>Clay & gravel</u>	<input checked="" type="checkbox"/>	<u>140</u>	<u>155</u>	

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 155 feet
10 inches
Casing record 155 ft
Weight per foot 6 Thickness 156
Diameter From To
6 inches 0 feet 155 feet
Surface seal: Yes No Type Cast
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 155 feet to 80 feet
Perforations:
Type perforation Traylor Peef
Size perforation 3 X 5/32"
From 138 feet to 155 feet

Date started 8-21, 1989
Date completed 8-22, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>20.7</u>	<u>22</u>	<u>68</u>

9. WATER LEVEL
Static water level 102 feet below land surface
Flow 20.7 G.P.M. P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge
Name Kowchuck Drilling Inc. Contractor
Address PO Box 538 Gardnerville NV 89410 Contractor
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada contractor's driller's number issued by the Division of Water Resources #1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen
By driller performing actual drilling on site or contractor
Date 8-27-89

BAILER TEST
G.P.M. 20.7 Draw down 5 feet 1 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours