

OFFICE USE ONLY
 Log No. 32176
 Permit No. 6-83
 Basin. 13018

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13018

1. OWNER Robert & Janelle Williamson ADDRESS AT WELL LOCATION 440 Highland Rd
 MAILING ADDRESS 440 Highland Rd Lot 44
 Reno, Nv 89511
 2. LOCATION SE 1/4 se 1/4 Sec 6 T 17 N/S R 21 E Storey County
 PERMIT NO. 3-431-06 - Highland Ranches
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
Hard fractured granite		2	48	46
D.G. with blue clay		48	63	15
Hard gray sandstone		63	112	49
Hard multi-colored D.G.		112	170	58
Loose gray sandstone		170	190	20
Hard gray sandstone with occasional clay stringers		190	270	80
Hard gray sandstone with frequent fractures		270	320	50
T.D. 320 ft				

8. 10" - 50' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 320 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+1 feet	320 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 320 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 2
 From 280 feet to 300 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Date started 8/28/89
 Date completed 8/29/89

9. WATER LEVEL
 Static water level 205 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlifted at 110 PSI for 1 1/2 hrs and develop. Approx 20+ GPM			to clean

03:00 SEP 12 1989

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L Sparks, NV 89431 Contractor
 Nevada contractor's license number 15291 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1037
 Signed Roger M. Thrall By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 9/5/89

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours