

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13011

PRINT OR TYPE ONLY

1. OWNER Greg Dean ADDRESS AT WELL LOCATION Saddleback
 MAILING ADDRESS P. O. Box 7252 Mammoth Lake, Ca 93546 Block M Lots 291 & 292
 2. LOCATION NE 1/4 NE 1/4 Sec 31 T. 18 N/S R. 21 E Washoe County Virginia City Highlands
 PERMIT NO. 3-101-01 - Subdivision Name _____
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Multicolored D.G. hard with brown clay		0	152	152
Hard blue granite with brown clay		152	254	102
Hard grey blue sandstone - highly fractured	XX	254	300	41
T.D. 300 ft				

8. 10" - 50' WELL CONSTRUCTION
 Diameter 8 3/4 inches Total depth 295 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1</u> feet	<u>295</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 295 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 275 feet to 295 feet
 From _____ feet to _____ feet

Date started 8/23/89, 19____
 Date completed 8/24/89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>100</u>	<u>10</u>	<u>125</u>	<u>125</u>
<u>Air lifted for 40 minutes at 125 PSI to clean and develop.</u>			
<u>100</u>	<u>10</u>	<u>125</u>	<u>125</u>

9. WATER LEVEL
 Static water level 130 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1037
 Signed Roger M. Thrall
 By Roger M. Thrall driller performing actual drilling on site or contractor
 Date 8/25/89

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____