WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32/89
Permit No. 39291
Basin 6-21

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13027

1. OWNER Verdi Business Park
MAILING ADDRESS P. O. Box 830
Verdi, Nv 89439

ADDRESS AT WELL LOCATION 2465 Old Highway 40

2. LOCATION NE ¼ ¼ NE ¼ Sec. 16 T. 19 N/S R. 18 E. Washoe County
PERMIT NO. 39291 (Issued by Water Resources) 38-430-17 (Parcel No.) — (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary XX
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blue to gray volcanic material with blue clay & volcanic ash		195	206	11
Blue & black volcanic material with frequent fracutres		206	300	94
Volcanic material with frequent fractures	X	300	365	
T.D. 365 ft				

Date started 8/18/89, 19
Date completed 8/22/89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlifted for 1½ hours at 120 PSI to clean and develop. Approx. 50 to 60 GPM			

STATE ENGINEERS OFFICE
'89 SEP 12 AM 10:31

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6½ inches Total depth 365 feet
..... inches
..... inches
Casing record 5 inch
Weight per foot 6.96 Thickness .134

Diameter	From	To
5 inches	185 feet	365 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 325 feet to 365 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 125 feet below land surface
Flow 50-60 G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc. (Contractor)
Address 625 Spice Islands Dr Suite L Sparks, Nv 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1037
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 8/23/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627