WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 32199
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12159

1. OWNER LONNIE MOORE
MAILING ADDRESS [redacted] LANE P.O. BOX 223
FALLON, NV 89406

ADDRESS AT WELL LOCATION [redacted]
RIVERS EDGE DRIVE

2. LOCATION SE ¼ NW ¼ Sec. 29 T. 19 N/S R. 28 E/W CHURCHILL County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY | | 0 | 11 | 11 |
| SAND | X | 11 | 28 | 17 |
| GRAY SAND & CLAY | X | 28 | 62 | 34 |
| SAND | X | 62 | 87 | 25 |
| CLAY | | 87 | 91 | 4 |
| GRAY SAND | X | 91 | 116 | 25 |
| CLAY | | 116 | 120 | 4 |
| COARSE SAND & GRAVEL | X | 120 | 139 | 19 |

Date started AUGUST 8, 1989
Date completed AUGUST 9, 1989

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| AIR BLOWN @ 40 GPM | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 139 feet
inches
inches
Casing record 6 5/8 X 139
Weight per foot 12.9 Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 139 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes [X] No [ ] Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from feet to feet

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32 X 3
From 134 feet to 137 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 59 °F Quality UNKWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP Contractor
Address P. O. BOX 888 FALLON, NV 89406 Contractor
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed [signature] By driller performing actual drilling on site or contractor
Date AUGUST 10, 1989

(Rev. 11 85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627