

OFFICE USE ONLY
 Log No. 32221
 Permit No. 7-92a
 Basin. 7-92a
 NOTICE OF INTENT NO. 13029

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER Union Pacific/Uplands Corp ADDRESS AT WELL LOCATION Lear Blvd
 MAILING ADDRESS 2710 Gate Way Oaks Suite 150 Lot 4 Block C
Sacramento, Ca 95833

2. LOCATION NE 1/4 SW 1/4 Sec 31 T 21 N/S R 19 E Washoe County Washoe
 PERMIT NO. 90-050-31 Silver Lake Business Center
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK Abandonment 4. PROPOSED USE 5. TYPE WELL

New Well <input type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/>	Irrigation <input checked="" type="checkbox"/>	Test <input type="checkbox"/>	Cable <input type="checkbox"/>	Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Removed 5 ft piece of 10 3/4 inch casing slipped over top of 8 5/8 inch casing. Run 1 inch trimie tube to depth of 29 ft jetted with approximately 85 gallons of water to depth of 39 feet. Neat cement pumped from 39 feet to land surface. Approximately 75% of 1 yard of cement used to bring slurry to the surface, 25% was pumped above surface. Trimie pipe removed from well.				
LBS of neat cement -	3,782.85			

8. WELL CONSTRUCTION

Diameter.....inches Total depth.....39 feet

Casing record 9 ft below land surface 8 5/8 inch
 Weight per foot..... Thickness.....

Diameter	From	To
.....inchesfeetfeet

Surface seal: Yes No Type.....
 Depth of seal.....feet
 Gravel packed: Yes No
 Gravel packed from.....feet to.....feet

Perforations:
 Type perforation.....
 Size perforation.....
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Date started 8/16/89, 19.....
 Date completed 8/16/89, 19.....

9. WATER LEVEL

Static water level.....feet below land surface
 Flow.....G.P.M.P.S.I.
 Water temperature.....°F Quality.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed Roger M. Thrall By driller performing actual drilling on site or contractor
 Date 8/17/89