WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 32240
Permit No.
Basin 4-51

**PRINT OR TYPE ONLY**

NOTICE OF INTENT NO.

1. OWNER Newmont Gold
MAILING ADDRESS Box 669
Carlin, Nv. 89822-0669
ADDRESS AT WELL LOCATION G.R.C. - 355W
2. LOCATION SE ¼ NW ¼ Sec. 35 T. 34 N/S R. 51 E Eureka County
PERMIT NO. M/o-155 (Issued by Water Resources) Parcel No. Gold Quarry Mine (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Siltstone | | 0 | 605 | 605 |
| Limestone | | 605 | 810 | 205 |

'89 AUG 25 A10:17
STATE ENGINEER'S OFFICE

Date started 8-1, 19 89
Date completed 8-7, 19 89

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| — | — | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 5 3/4 inches Total depth 810 feet
..... inches
..... inches
Casing record PVC
Weight per foot ..... Thickness Sch 80

| Diameter | From | To |
|---|---|---|
| 1 inches | 0 feet | 803 feet |
| 1 inches | 0 feet | 585 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement-Bentonite
Depth of seal 0-50 ft. 500-520 feet 592-727
Gravel packed: Yes ☒ No ☐
Gravel packed from 727-520 feet to 810-592 feet

Perforations:
Type perforation Slotted
Size perforation 0.01 in.
From 763 feet to 803 feet
From 565 feet to 585 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 328 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature 72 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Austin Corp. (Contractor)
Address Box 894, Elko, Nev (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0022193
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 802
Signed Everett D. Austin (By driller performing actual drilling on site or contractor)
Date 8-24-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627