


OFFICE USE ONLY
Log No. 32287
Permit No. _____
Basin 218



WELL DRILLER'S REPORT *book*

Please complete this form in its entirety

NOTICE OF INTENT NO. 5322

PRINT OR TYPE ONLY

1. OWNER Nevada Power ADDRESS AT WELL LOCATION Upper Muddy River Valley
MAILING ADDRESS Las Vegas - Nev
2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 14 N. 65 E. Clark County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Other
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
75% fine gravel to cobble 25% very fine sand		0		
100% fine siltstone		12	12	12
99% fine siltstone + 1% small gravel		28 1/2	28 1/2	16 1/2
60% rounded small to coarse sandstone pebbles + 40% fine siltstone		34	34	5 1/2
100% fine siltstone		46	46	12
50% sandstone + claystone		55	55	9
100% fine siltstone		55	66	11
100% fine med well rounded Qtz Arenite		66	69	3
100% fine siltstone		69	72	3
100% fine very fine sandstone		72	73	1
100% fine silt + claystone		73	82	9
100% fine Qtz Arenite		82	83	1
50% fine fine Qtz Arenite		83	84	1
50% silt + clay shale		84	84	1
100% fine silt + clay shale		84	92	8
50% fine fine Qtz Arenite		92	95	3
50% silt + clay shale		95	95	3
80% fine silt + clay shale		95	104	9
20% fine Qtz Arenite		104	104	9
100% fine siltstone + claystone		104	108	4

8. WELL CONSTRUCTION
Diameter 10" inches Total depth 108 feet
Casing record PVC
Weight per foot 5ch Thickness 80
Diameter 3 inches From 2 feet to 69 feet
Surface seal: Yes No Type Cement
Depth of seal 18 feet
Gravel packed: Yes No Natural
Gravel packed from _____ feet to _____ feet
Perforations:
Type perforation HACKSAW BLADE
Size perforation _____
From 28 feet to 69 feet
From _____ feet to _____ feet

Date started 12/05/87 1987
Date completed 12/07/87 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
JAN 05 1988

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
Static water level _____ feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Environmental Contractor
Address 16018 Valley Blvd Fontana, CA 92335
Nevada contractor's license number issued by the State Contractor's Board _____
Nevada contractor's driller's number issued by the Division of Water Resources _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1468
Signed Stephen Johnson
By driller performing actual drilling on site of contractor
Date 12/16/87