WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32310
Permit No. 49866
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2815

1. OWNER Robert Berkman
MAILING ADDRESS 9501 W. Sahara, Apt.2221,Bldg. 34
Las Vegas, NV 89177

ADDRESS AT WELL LOCATION 6676 No. Tioga Way

2. LOCATION NW ¼ SW ¼ Sec. 22 T. 19 S R. 60 E Clark County
PERMIT NO. 49866 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐ Quasi

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	20	20
White clay		20	40	20
Clay & gravel mix		40	180	140
Gravel		180	240	60
Red clay		240	260	20
Sandy clay		260	340	80
Red clay		340	360	20
Gravel		360	420	60
Red sandy clay		420	440	20
Red sandy clay & grav. mix		440	460	20

RECEIVED
AUG 31 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

'89 AUG 28 A9:41
STATE ENGINEER'S OFFICE

Date started July 13, 1989
Date completed July 31, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 460 feet
____ inches
____ inches
Casing record
Weight per foot ____ Thickness .188

Diameter	From	To
8 inches	+1 feet	460 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 460 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8"
From 360 feet to 460 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 117 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1489
Signed Richard K. Thompson (By driller performing actual drilling on site of contractor)
Date August 25, 1989

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627