WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33318
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER CALNEV Pipeline Co.
MAILING ADDRESS 5049 N. Sloan Ln LV
Las Vegas, NV 89115

ADDRESS AT WELL LOCATION MW-1

2. LOCATION SE ¼ SE ¼ Sec. 33 T. 19 S N/S R. 62 E. Clark County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒ Monitor
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand w clay		0	11'	11'
Silty Clay / Clayey Silt		11'	140'	129'

RECEIVED
JUN 19 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-5, 1989
Date completed 12-6, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 140 feet
inches
inches
Casing record Surface to 140'
Weight per foot ..... Thickness Sch 40 PVC

Diameter	From	To
2 inches	Surface feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type NEAT CEMENT
Depth of seal 93 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 93 feet to 140 feet

Perforations:
Type perforation Factory Slotted Screen
Size perforation .020 inch
From 97 feet to 137 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 106.3 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Converse Consultants (Contractor)
Address 4670 South Polaris Avenue Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed Donald J. [illegible] (By driller performing actual drilling on site or contractor)
Date 6-9-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627