WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32339
Permit No.
Basin 212

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3079

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 3700 West Charleston Blvd.
Las Vegas, NV 89153

ADDRESS AT WELL LOCATION MW-6

2. LOCATION NE ¼ NE ¼ Sec. 21 T 20 N (S) R 62 E Clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE (Monitor)
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand		0'	12'	12'
Silty Clay		12'	20'	8'
Clayey Sand		20'	23'	3'
Clayey Sand & Gravel		23'	32'	9'

RECEIVED
JUL 03 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-31, 19 89
Date completed 5-31, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 32 feet
inches
inches
Casing record 0' - 30'
Weight per foot ..... Thickness Sched. 40 PVC

Diameter	From	To
4 inches	0 feet	30 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete grout
Depth of seal 6 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 6 feet to 32 feet

Perforations:
Type perforation factory slotted screen
Size perforation 0.020 inch
From 10 feet to 30 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Converse Consultants (Contractor)
Address 4670 S. Polaris Ave., Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/10/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627