WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32344
Permit No.
Basin

NOTICE OF INTENT NO. 5789

PRINT OR TYPE ONLY

1. OWNER TOM WOOD
MAILING ADDRESS P.O. BOX 1481 PAHRUMP, NV. 89041

ADDRESS AT WELL LOCATION PLUTO WEST OF VICKIE AVE, PAHRUMP, NV.

2. LOCATION S.E. ¼ N.E. ¼ Sec. 2 T. 21 S R. 53 E. NYE County
PERMIT NO. Issued by Water Resources | LOT 28 BLK E Parcel No. | GAMEBIRD Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD WHITE CALICHE		1	5	4
HARD BROWN CALICHE		5	19	14
BROWN CALICHE		19	31	12
HARD BROWN CALICHE		31	55	24
BROWN CALICHE		55	58	3
HARD BROWN CALICHE		58	67	9
BROWN CLAY W/		67	101	34
LAYERS BR. CALICHE				
HARD BROWN CALICHE		101	114	13
BROWN CLAY		114	120	6
HARD BROWN CLAY		120	134	14
BENTONITE CLAY		134	140	6

RECEIVED
JUL 18 1989
Div. of Water Resources
Branch Office: Las Vegas, NV

Date started 6-28, 1989
Date completed 7-7, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 140 feet
inches
inches
Casing record 140' 8 5/8" O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation
From 80 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 38 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING (Contractor)
Address BOX 157 PAHRUMP, NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7479-A
Nevada contractor's driller's number issued by the Division of Water Resources 1424
Nevada driller's license number issued by the Division of Water Resources, for on-site driller 1427 - STAN HARDIN
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-10-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627