

OFFICE USE ONLY
 Log No. 32351
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 5787

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER ART BELL ADDRESS AT WELL LOCATION MANSE WEST OF HAFEN RANCH RD.
 MAILING ADDRESS P.O. BOX 2360 PARRUMP, NV. 89041
 2. LOCATION N. 1/4 N.E. 1/4 Sec. 9 T. 21 R. 54 E. NVE County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____
 Subdivision Name CHRISTIANSEN

RECEIVED
 JUN 3 11 25 AM '89
 Div. of Water Resources
 Branch Office - Las Vegas

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 Proposed Use: Irrigation Industrial Test Stock Domestic Municipal
 5. TYPE WELL
 Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	Thick-ness
SANDY LOAM		0	6
HARD BROWN CLAY		6	9
BROWN CLAY		9	18
HARD BROWN CLAY		18	24
BROWN CLAY		24	29
HARD BROWN CLAY		29	36
GRAVEL + ROCKS		36	43
BROWN CLAY		43	49
GRAVEL + ROCKS		49	53
BENTONITE CLAY		53	60
HARD BROWN CLAY		60	69
BROWN CLAY		69	75
HARD BROWN CLAY		75	96
BROWN CLAY + ROCKS		96	104
HARD BR. CLAY + ROCKS		104	113
BROWN CLAY + ROCKS		113	122
HARD BR. CLAY + ROCKS		122	129
BROWN CLAY		129	160
HARD BR. CLAY + ROCKS			31

8. WELL CONSTRUCTION
 Diameter 12 inches Total depth 160 feet
 Casing record 160 FT. 8 7/8" O.D. STEEL
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 7/8</u> inches	<u>0</u> feet	<u>160</u> feet

 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation TORCH CUT
 Size perforation 1/2" X 6"
 From 80 feet to 160 feet

Date started 6-6, 1989
 Date completed 6-15, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 44 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ROD FLOYD PUMP & DRILLING Contractor
 Address BOX 157 PARRUMP, NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 7479-A
 Nevada contractor's driller's number issued by the Division of Water Resources 11424
 Nevada driller's license number issued by the Division of Water Resources 1427 STAN HARDIN
 Signed _____ By driller performing actual drilling on site or contractor
 Date 6-19-89