

OFFICE USE ONLY  
 Log No. 32362  
 Permit No. 212  
 Basin 212

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2654

PRINT OR TYPE ONLY

1. OWNER Herbst Oil Company ADDRESS AT WELL LOCATION SMP-6  
 MAILING ADDRESS 5195 Las Vegas Blvd. South  
Las Vegas, Nevada 89119  
 2. LOCATION NE 1/4 NE 1/4 Sec. 10 T. 21 N. R. 61 E Clark County  
 PERMIT NO. MD-2009 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation   
 Municipal  Industrial   
 Monitor  Test   
 Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0'	2'	2'
Caliche		2'	3'	1'
Sandy Clay		3'	6'	3'
Clayey silt		6'	8'	2'
Clay		8'	11'	3'
* No returns, drills like clay		11'	26'	15'

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 26 feet  
 Casing record Surface to 25  
 Weight per foot \_\_\_\_\_ Thickness Sched. 40 PVC  

Diameter	From	To
<u>4</u> inches	<u>0</u> feet	<u>25</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type portland cement  
 Depth of seal 2 feet  
 Gravel packed: Yes  No   
 Gravel packed from 2 feet to 26 feet  
 Perforations:  
 Type perforation factory slotted screen  
 Size perforation 0.020 inch  
 From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 JUN 9 1988  
 Div. of Water Resources  
 Branch Office - Las Vegas NV

Date started 6-8 19 89  
 Date completed 6-8 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
 Flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Don Wilson / Converse Consultants Contractor  
 Address 4670 S. Polaris Ave. Las Vegas, NV Contractor  
89103  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589  
 Signed Don Wilson By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_