WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32369
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2619

1. OWNER Herbst Oil Company
MAILING ADDRESS 5195 Las Vegas Blvd. South Las Vegas, Nevada 89119
ADDRESS AT WELL LOCATION SMP3

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2009 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒ Monitor
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy loam | | 0' | 1' | 1' |
| Gravelly, sandy clay | | 1' | 6' | 5' |
| Caliche | | 6' | 7' | 1' |
| Clayey Sand | | 7' | 22' | 15' |

RECEIVED
JUN 19 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-1, 19 89
Date completed 5-1, 19 89

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 22 feet
..... inches
..... inches
Casing record surface to 20'
Weight per foot ..... Thickness Sched. 40 PVC

| Diameter | From | To |
|---|---|---|
| 4 inches | 0 feet | 20 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type portland cement
Depth of seal 3 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 3 feet to 22 feet

Perforations:
Type perforation factory slotted screen
Size perforation 0.020 inch
From 5 feet to 20 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 7 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Converse Consultants (Contractor)
Address 4670 S. Polaris Ave. Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed [signature] (By driller performing actual drilling on site or contractor)
Date .....

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627