

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 12989

PRINT OR TYPE ONLY

1. OWNER William Burnaugh ADDRESS AT WELL LOCATION TOPAZ PARK RD. & AUSTIN STREET LAKE TOPAZ
 MAILING ADDRESS PO BOX 787
CARSON CITY, NEV. 89701

2. LOCATION SE 1/4 NW 1/4 Sec. 29 T. 10 N/S R. 22 E. Douglas County
 PERMIT NO. 39-200-09 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MULTI-COLORED ROCKS</u>		<u>0</u>	<u>85</u>	<u>85</u>
<u>Brown clay</u>		<u>85</u>	<u>89</u>	<u>4</u>
<u>MULTI-COLORED ROCKS MIXED W/CLAY</u>	<input checked="" type="checkbox"/>	<u>89</u>	<u>115</u>	<u>26</u>
<u>Brown clay</u>		<u>115</u>	<u>119</u>	<u>4</u>
<u>gravel</u>	<input checked="" type="checkbox"/>	<u>119</u>	<u>153</u>	<u>32</u>
<u>Brown clay</u>		<u>153</u>	<u>156</u>	<u>3</u>

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 156 feet
 Casing record _____ Thickness 188
 Weight per foot _____
 Diameter From To
8 inches 0 feet 156 feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 156 feet

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 1/8" x 3" 6 pr/ft
 From 116 feet to 156 feet

Date started 10-5 1989
 Date completed 10-7 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 82 feet below land surface
 Flow 0 G.P.M. 30 approx P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Energy Exploration Contractor
 Address Po Box 1538 Minden NV 89423 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 21491
 Nevada contractor's driller's number issued by the Division of Water Resources 1407
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407
 Signed Sam Woods
 By driller performing actual drilling on site or contractor
 Date 10-9-89

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours