WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32395
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13428

1. OWNER Tom Doherty Const
MAILING ADDRESS 1976 Sorrel Lane
Gardnerville, Nevada

ADDRESS AT WELL LOCATION
1187 Autumn Hills Road
Gardnerville, Nevada

2. LOCATION NW ¼ NW ¼ Sec. 10 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 19-350-04 Parcel No. | Cary Creek Estates Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ large boulders & sand		0	17	17
Granite, hard		17	29	12
D.G. Soft to medium hard		29	34	5
Granite broken with sand layers		34	140	106
Sand, Course to very fine with water	✓	140	149	9
Broken, hard granite, course to semi-fine sand	✓	149	160	11
T.D. 160 Ft				

Date started Oct 16, 1989
Date completed Oct 19, 1989

7. WELL TEST DATA

STATE ENGINEERS OFFICE
RECEIVED
89 OCT 24 P3:56

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove drill mud & gravel pack, Developed with 450 250 air for 2 Hrs Blew 30 GPM from 140 feet			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 12" to 69 7/8 inches Total depth 160 feet
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to ____ feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 140 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 86 feet below land surface
Flow 30+ G.P.M. ____ P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co
Contractor
Address Carson City, NV 89701
Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number ____
Nevada driller's license number 1472
Actual Driller
Signed Quinton Butts
Contractor
Date Oct 20, 1989

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434