WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32404
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13427

1. OWNER Greg Davies Const
MAILING ADDRESS Box 22
Gardnerville, Nevada

ADDRESS AT WELL LOCATION
1054 Tybo ~~Tonaha~~ Street
Gardnerville, Nevada

2. LOCATION ~~NE~~ NW ¼ SE ¼ Sec 12 ~~23~~ T 12 N/S R 20 E Douglas County
PERMIT NO. 23-232-09 Sagewood Estates
Issued by Water Resources | Parcel No. (new apn #1220-12-710-040) | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air & mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ gravels		0	9	9
Cemented pea gravels with tight clay seams		9	193	184
Gravels, fine to coarse w/ sand lenses 1-3 GPM, tight, hard	✓	193	221	28
Gravels, fine to coarse w/ fine sand	✓	221	239	18
Tight hard clay		239	240	1
T.D. 240'				

23-232-09 is 1054 Tybo Ct
Legal is NW SE Sec 12 12N 20E
If old APN number is correct street # is wrong [redacted]

Date started Oct 6, 1989
Date completed Oct 12, 1989

STATE ENGINEER
OCT 16 AM 10:36
89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Gravel packed & developed with air. Blew 15 GPM for 2 hours from 225'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17" 6.60 inches Total depth 240 feet
Casing record 6 5/8 steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Redi-mix
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 240 feet

Perforations:
Type perforation Factory slot
Size perforation 3/32 x 3"
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 160 feet below land surface
Flow 18 G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H pump Co
Contractor
Address Carson City, NV
Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Actual Driller
Signed Quinton P. Betts
Contractor
Date Oct 13, 1989

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY O-627 CR434