

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1271

PRINT OR TYPE ONLY

1. OWNER Ray Baker ADDRESS AT WELL LOCATION 1111 N. 1st St. Las Vegas, NV  
 MAILING ADDRESS 1111 N. 1st St. Las Vegas, NV  
 2. LOCATION NE NW  $\frac{1}{4}$  Sec 19 T 11 N/S R. 22 E. Clark County  
 PERMIT NO. 19498 Issued by Water Resources Parcel No. 1111 Subdivision Name 1111

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	2	
Clay & sand		2	5	
Gravel	X	35	50	
Clay & sand		50	100	
Clay & sand		100	150	
Clay & sand		150	200	
Clay & sand		200	250	
Clay & sand		250	300	

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 310 feet  
 Casing record  
 Weight per foot 9.7 Thickness 1.56  

Diameter	From	To
8 inches		140 feet
8 inches		feet
8 inches		feet
8 inches		feet
8 inches		feet
8 inches		feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 10 feet  
 Gravel packed: Yes  No   
 Gravel packed from 10 feet to 50 feet  
 Perforations:  
 Type perforation 1 1/2" x 1 1/2"  
 Size perforation 3/8" x 3/8"  
 From 250 feet to 310 feet  
 From 250 feet to 310 feet

Date started 10-11-89  
 Date completed 10-11-89, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>100</u>	<u>1.00</u>	<u>68</u>	

9. WATER LEVEL  
 Static water level 250 feet below land surface  
 Flow 1.00 G.P.M. 0 P.S.I.  
 Water temperature 62.4 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ray Baker Contractor  
 Address P.O. Box 935 Clark Co NV 89402 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board #1203  
 Nevada contractor's driller's number issued by the Division of Water Resources #1350  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1475  
 Signed Ray Baker  
 By driller performing actual drilling on site or contractor  
 Date 10-19-89

BAILER TEST  
 G.P.M. 1.00 Draw down 68 feet 1 hours  
 G.P.M. 1.00 Draw down 68 feet 1 hours  
 G.P.M. 1.00 Draw down 68 feet 1 hours