

OFFICE USE ONLY
 Log No. 32447
 Permit No. _____
 Basin 7-926

WELL DRILLER'S REPORT
 Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER JEFFREY P. & SUSAN P. SULLIVAN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6898 S. Roslyn Cir. 11000 Fir drive
Englewood, CO. 80112 Reno, NV 89506
 2. LOCATION SE 1/4 SE 1/4 Sec. 23 T. 21N N/S R 19 E Washoe County
Lemmon Valley
 PERMIT NO. _____ Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Total depth - $3\frac{1}{2}$ GPM at 185 ft.				
Gray hard granite		185	253	68
Soft zone (NO WATER)		253	255	2
Gray hard granite		255	283	28
Small fracture(app 1GPMX)		283	283 $\frac{1}{2}$	$\frac{1}{2}$
Gray hard granite		283 $\frac{1}{2}$	352	68 $\frac{1}{2}$
Soft zone(app $\frac{1}{2}$ GPM)	X	352	355	3
Gray hard granite		355	376	21
Fracture (app 2 $\frac{1}{2}$ GPM)	X	376	377	1
Gray hard granite		377	400	23

Deepening of log # 26365

8. WELL CONSTRUCTION

Diameter 5 inches Total depth 400 ft

Casing record 400' steel casing installed.
 Weight per foot _____ Thickness .134

Diameter	From	To
5" OD inches	0	400
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type N/A

Depth of seal _____ feet

Gravel packed: Yes No fractures in granite

Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around

From	feet to	_____ feet
174	194	_____ feet
294	314	_____ feet
334	354	_____ feet
374	394	_____ feet
_____	_____	_____ feet

Date started 10-11-89, 19_____
 Date completed 10-13-89, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

15:6V #2 130 68

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 53 feet below land surface
 Flow 7 $\frac{1}{2}$ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada contractor's driller's number issued by the Division of Water Resources 908

Nevada driller's license number issued by the Division of Water Resources 923 the on-site driller.

Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor
 Date October 20, 1989