


OFFICE USE ONLY  
 Log No. 32501  
 Permit No. \_\_\_\_\_  
 Basin 21A



**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2130

PRINT OR TYPE ONLY

1. OWNER GILBERT A. GONZALES ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE NW 1/4 SE 1/4 Sec. 35 T. 19S N/S R. 61 E. CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SURFACE SOIL</u>		<u>0'</u>	<u>6'</u>	<u>6'</u>
<u>CALICHE</u>		<u>6'</u>	<u>18'</u>	<u>12'</u>
<u>WHITE SANDY CLAY</u>		<u>18'</u>	<u>48'</u>	<u>30'</u>
<u>RED SAND - CLAY WATER</u>	<u>60'</u>	<u>48'</u>	<u>98'</u>	<u>50'</u>
<u>WHITE CLAY</u>		<u>98'</u>	<u>208'</u>	<u>110'</u>
<u>RED CLAY</u>		<u>208'</u>	<u>300'</u>	<u>92'</u>

8. WELL CONSTRUCTION  
 Diameter hole SIX inches Total depth 300 feet  
 Casing record 300' OF SIX INCH CASING  
 Weight per foot 15 Thickness 10 GAUGE

Diameter	From	To
<u>SIX</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type CONCRETE  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 300 feet

Perforations:  
 Type perforation TORCH  
 Size perforation 3" LONG X 3/16 WIDE

From 210 feet to 290 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 OCT 19 1989

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started APRIL 28 1989  
 Date completed AUG. 19 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>21</u>	<u>28</u>	<u>2</u>	<u>6</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 62'/60' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name R.C.B.B. INC. Contractor  
 Address \_\_\_\_\_ Contractor  
 Nevada contractor's license number 020301  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 1268 Actual Driller  
 Signed R.C.B.B. INC. Contractor  
 Date Oct. 12, 1989